

ADDENDUM NO. 1

NAME: SWMA004-2020-Replacement of Roll –Up Doors at North Hempstead Transfer Station

DATE: August 10, 2020

TO: All Prospective Proposers

1. Is the one door in the MSW and Recycling Area being replaced in Phase 1 to be a high speed door or a regular steel door?

That door will be a regular steel door

2. The Albany RR1500 is listed in the bid document as one of the acceptable High Speed Door models. However, per the manufacturer's website, several of the door sizes required for this project exceed the Albany RR1500's maximum size limitations (20'0" wide x 24' high). Can you please clarify?

The vendor will have to check with the manufacturer to see if they provide doors in the required sizes. If doors are not available in the sizes in the Request for Bid then a substitution can be done as long as specifications are reached

3. The Albany Model 300 is listed in the bid document as an acceptable Steel Door. However, there is no mention of this model on the manufacturer's website. Can you please confirm if this is the correct model?

Albany Model 300 listed in the Request for Bid was meant to be United Steel Products Model 300. However the vendor is allowed to substitute with another manufacturer's door as long as the Authority's specifications are satisfied

4. Will a bid bond be required?

No bid bond is required.

5. Are the performance and payment bonds for Phase 1 only?

Bidders must provide performance and payment bonds that cover both phases of the project. Bidders can supply bonds that cover both phases or separate bonds for separate phases.

6. Will TNH supply bonding forms?

Bidders may use standard AIA Form A312-2010 performance and payment bonds. Bidders should reach out to their sureties on this matter.

7. What will dictate phase one being completed in one year? Only our ability to supply and install the doors or are there other factors from TNH side?

The bid document does not state that each phase must be completed within a year. The proposal form states that work must be completed within 60 days of a notice to proceed. However, this should read 120 days. The Authority is not aware of any factors on the Authority's side that would affect this timeline.

The "ADDENDUM NO. 1 RECEIPT ACKNOWLEDGEMENT FORM" on the last page of this Addendum NO. 1 must be signed and dated in the spaces provided and submitted with your Proposal. All Proposers must submit this form with its Proposal regardless of the content contained in each Addendum

ADDENDUM NO.1 RECEIPT ACKNOWLEDGEMENT FORM

SWMA004-2020-Replacement of Roll –Up Doors at North Hempstead Transfer Station

By signing this Acknowledgement and submitting same with its Proposal submission, the undersigned Proposer acknowledges receipt of this Addendum No. 1. Proposer further acknowledges that it has read and reviewed the information contained herein, understands same, and that its questions, if any presented, have been answered satisfactorily. Proposer agrees that it shall incorporate/consider the information contained in this Addendum No. 1 in preparing and providing its proposal price. In addition, this Addendum No.1 Receipt Acknowledgement Form must be signed and dated and attached to the proposal submittal.

Signature: _____

Company Name: _____

Proposer Acknowledgement Date: _____

Print & Sign Company Principal Name & Title: _____
